



CHINA QUALITY CERTIFICATION CENTRE  
CERTIFICATE OF CONFORMITY

Certificate No.: CE190306006184

**Product** Automatic transfer switching equipment

**Applicant** NOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai,  
P.R.China

**Type/Model** ExATS9M1-S,ExATS9M1-N,ExATS9M1-R

**Technical data** See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2019CQC0306-010064, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:  
2014/35/EU

Valid from: Feb.19,2019

Valid until: Feb.19,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0009340



CHINA QUALITY CERTIFICATION CENTRE  
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE190306006184

ExATS9M1-S,ExATS9M1-N,ExATS9M1-R  
Uimp: 8kV;  
Ui: 800V;  
Ith: 16A,20A,25A,32A,40A,50A,63A,80A,100A,125A;  
Ue: AC400V;  
Ie: 16A,20A,25A,32A,40A,50A,63A,80A,100A,125A;  
Utilization category:AC-32B;  
Icm: S:75.6kA,N:105kA,R:187kA;  
Icn: S:36kA,N:50kA,R:85kA;  
class of equipment: CB;  
method of controlling: ATSE;  
3P, 4P  
IP20(except for the terminals)

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>