



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Certificate No.: CE190306006182

Product Automatic transfer switching equipment

Applicant NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai,
P.R.China

Type/Model ExATS9M3-S,ExATS9M3-N,ExATS9M3-R

Technical data See the Appendix

This is to certify that, on the basis of the tests undertaken as per Report No. 00901-CE2019CQC0306-010062, the submitted sample(s) of the above item complies with:

EN 60947-6-1:2005 + A1:2014

and fulfills testing requirements of the European Directive:
2014/35/EU

Valid from: Feb.19,2019

Valid until: Feb.19,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

CE 0009338



CHINA QUALITY CERTIFICATION CENTRE
CERTIFICATE OF CONFORMITY

Appendix

Page 1 of 1

Certificate No.: CE190306006182

ExATS9M3-S,ExATS9M3-N,ExATS9M3-R;
Uimp: 8kV;
Ui: 800V;
Ith: 250A,315A,350A,400A;
Ue: AC400V;
Ie: 250A,315A,350A,400A;
Utilization category:AC-32B;
Icm: S:75.6kA,N:105kA,R:187kA;
Icn: S:36kA,N:50kA,R:85kA;
class of equipment: CB;
method of controlling: ATSE;
3P, 4P;
IP20(except for the terminals)

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>