



CHINA QUALITY CERTIFICATION CENTRE  
CERTIFICATE OF CONFORMITY

Certificate No.: CE190306006198

**Product** Automatic transfer switching equipment

**Applicant** NOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

**Type/Model** ExATS9M4-S,ExATS9M4-N,ExATS9M4-R,ExATS9M5-S,ExAT  
S9M5-N,ExATS9M5-R

**Technical data** Uimp: 8kV;Ui: 800V; Ith:  
ExATS9M4:400A,500A,630A;ExATS9M5:700A,800A;Ue: AC400V;  
Ie: ExATS9M4:400A,500A,630A;ExATS9M5:700A,800A;  
Utilization category:AC-32B; Icm: S:75.6kA,N:105kA,R:187kA; Icn:  
S:36kA,N:50kA,R:85kA; class of equipment: CB; method of  
controlling: ATSE; 3P, 4P;IP20(except for the terminals)

This is to certify that, on the basis of the tests undertaken as per Report No.  
00901-CE2019CQC0306-010061, the submitted sample(s) of the above item complies with:  
**EN 60947-6-1:2005 + A1:2014**  
and fulfills testing requirements of the European Directive:  
**2014/35/EU**

Valid from: Feb.28,2019

Valid until: Feb.28,2022

President:

Lu Mei



CHINA QUALITY CERTIFICATION CENTRE  
Section 9, No.188, Nanshuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>