

**IEC****IECEE**

Ref. Certif. No.

CN54669

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Thermal Overload Relay

Name and address of the applicant

NOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

Name and address of the manufacturer

NOARK Electrics (Shanghai) Co., Ltd.  
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.  
No.2 Changjiang Road, CHINT Intelligent Electric Appliance  
Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang  
Province, P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

Uimp:6kV;Ui: 690V;Ue: 690V; Ie: 160-225A,210-300A,280-400A,380-500A; Trip  
class:10A,3P;IP20(Front side); Auxiliary contact:(body contact)  
Ith:5A;AC-15:Ue/Ie:220V/1.64A,380V/0.95A; DC-13:Ue/Ie:220V/0.13A;INO1NC

Trademark / Brand (if any)

NOARK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Ex9R500;

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2021CQC-097671

This CB Test Certificate is issued by the National Certification Body

**CHINA QUALITY CERTIFICATION CENTRE**Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China  
Tel: +86-10-83886666 Fax: +86-10-83886282  
website: <http://www.cqc.com.cn>

Date: Sep.09,2021

Signature:

Xie ZhaoXu

**CB 0064309**