

IEC**IECEE**

®

™

Ref. Certif. No.

CN54668

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Thermal Overload Relay

Name and address of the applicant

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

Name and address of the manufacturer

NOARK Electrics (Shanghai) Co., Ltd.
No.3857 Sixian Road, Songjiang District, Shanghai, P.R.China

Name and address of the factory

Zhejiang CHINT Electrics Co., Ltd.
No.2 Changjiang Road, CHINT Intelligent Electric Appliance
Industrial Zone, North Baixiang Town, Yueqing City, Zhejiang
Province, P.R.China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Ui: 690V;Uimp:6kV;Ue: 690V;Ie:75-115A,110-150A,140-210A; Trip class:10A;3P;IP20(Front
side); Auxiliary contact:(body contact) Ith:5A;AC-15:Ue/Ie:220V/1.64A,380V/0.95A;
DC-13:Ue/Ie:220V/0.13A;1NO1NC

Trademark / Brand (if any)

NOARK

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

Ex9R185;

Additional information (if necessary may also be
reported on page 2)A sample of the product was tested and found
to be in conformity with

IEC 60947-4-1:2018

As shown in the Test Report Ref. No. which
forms part of this Certificate

00901-CB2021CQC-097658

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRESection 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China
Tel: +86-10-83886666 Fax: +86-10-83886282
website: <http://www.cqc.com.cn>

Date: Sep.09,2021

Signature:

谢肇旭

Xie ZhaoXu

CB 0064308